

Hi Sir,

In the report I attached with the budget, I said that only two purifiers had problems. One was for the house hold of Nicholas Juma, where the Red Tube for cleaning was cut by a child using razor blade. We sealed it with a cello tape and it is working. Next is Elisha Adhiambo's house where the tap for clean water collection (blue tap) is loose. It does not close completely. All the remaining purifiers are working well and most community members are now able to operate and care for the purifiers.

The rain started this week. People are planting in the village. The Marge Hill villagers have not recorded any incident of water borne diseases or water related diseases.

On Sunday we had a general meeting to teach people more on the issue of caring and maintenance of purifiers.

The villagers are earnestly looking forward to hear more from you.

This report is written by

Tom Nyangor.

Project coordinator.

NDHIWA